

FOR USE BY COMPETENT PERSONS

Anyone using this instrument should be knowledgeable and trained about the risks involved with measuring voltage, especially in an industrial setting, and the importance of taking safety precautions and of testing the instrument before and after using it to ensure that it is in good working condition.

**LVD2
VoltAlert
Safety Sheet**

Read First: Safety Information



To prevent possible electric shock, fire, or personal injury:

- Use the Product only as specified, or the protection supplied by the Product can be compromised.
 - Do not rely on the Product to detect the presence or absence of voltage on a conductor for safety purposes. A single pole non-contact voltage detector such as this Product is not suitable to determine if a circuit is hazardous. A volt meter or 2-pole voltage detector is necessary to confirm the absence of hazardous voltage prior to commencing work.
 - Do not use if the flashlight does not operate.
 - Detect a known voltage first to make sure that the Product operates correctly.
 - When using the Product if tip does not glow, voltage could still be present. The Product indicates active voltage in the presence of electric fields of sufficient strength generated from the source (MAINS) voltage. If the field strength is low, the Product may not provide indication of live voltages. Lack of an indication occurs if the Product is unable to sense the presence of voltage which may be influenced by several factors including, but not limited to:
 - Shielded wire/cables
 - Thickness and type of insulation
 - Distance from the voltage source
 - Fully-isolated users that prevent an effective ground
 - Receptacles in recessed sockets/ differences in socket design
 - Condition of the Product and Batteries
 - Disable the Product if it is damaged.
 - Do not use the Product if it is damaged.
 - Use Product with arrow visible.
 - Hold the Product behind the tactile barrier.
 - Do not use for dc voltage detection or around voltages exceeding 600 volts, or in the presence of variable motor drives.
 - Use caution with voltages above 30 V ac as a shock hazard may exist.
 - Do not stare or look directly at the LED flash light. The light is extremely bright.
 - Comply with local and national safety codes. Use personal protective equipment (approved rubber gloves, face protection, and flame-resistant clothes) to prevent shock and arc blast injury where hazardous live conductors are exposed.
 - Batteries contain hazardous chemicals that can cause burns or explode. If exposure to chemicals occurs, clean with water and get medical aid.
 - Remove the batteries if the Product is not used for an extended period of time, or if stored in temperatures above 50 °C. If the batteries are not removed, battery leakage can damage the Product.
 - Carefully read all instructions.
 - Read all safety information before you use the Product.
- For safe operation and maintenance of the product:
- Be sure that the battery polarity is correct to prevent battery leakage.
 - Repair the Product before use if the battery leaks.

Symbols

	Consult user documentation.
	Double Insulated.
	Hazardous Voltage. Risk of electric shock.
	Risk of danger. Important information.
	Conforms to European Union directives
	This product complies with the WEEE Directive and its marking requirements. The affixed label indicates that you must not discard this electrical/electronic product in domestic household waste. Do not dispose of this product as unsorted municipal waste. For information about take-back and recycling programs available in your country, see the Fluke website.
CAT IV	Measurement Category IV is applicable to test and measuring circuits connected at the source of the building's low-voltage MAINS installation.
	Battery

PN 4572337 September 2014 Rev. 2, 7/23
© 2014 -2023 Fluke Corporation. Specifications are subject to change without notice. All rights reserved.

Safety Specifications

- Altitude**2000 m
- Humidity**80 % for temperatures up to 31 °C decreasing linearly to 45 % relative humidity at 50 °C
- Electrical supply**1.5 Vdc 1x IEC LR03 AAA battery
- Temperature**0 °C to 50 °C
- Maximum Voltage to Earth**
- Ground**.....600 V
- Safety**IEC 61010-1:Pollution Degree 2. CAT IV 600V
- Electromagnetic Compatibility** IEC 61326-1: Portable Electromagnetic Environment; IEC 61326-2-2

CISPR 11: Group 1, Class A

Group 1: Equipment has intentionally generated and/or use conductively coupled radio-frequency energy which is necessary for the internal functioning of the equipment itself.

Class A: Equipment is suitable for use in all establishments other than domestic and those directly connected to a low voltage power supply network which supplies buildings used for domestic purposes. There may be potential difficulties in ensuring electromagnetic compatibility in other environments, due to conducted and radiated disturbances.

Caution: This equipment is not intended for use in residential environments and may not provide adequate protection to radio reception in such environments

Contacting Fluke

Fluke Corporation operates worldwide. For local contact information, go to our website: www.fluke.com.

To register your product, view, print, or download the latest manual or manual supplement, go to our website.

+1-425-446-5500
fluke-info@fluke.com.

LIMITED WARRANTY AND LIMITATION OF LIABILITY

This Fluke product will be free from defects in material and workmanship for two years from the date of purchase. This warranty does not cover fuses, disposable batteries, or damage from accident, neglect, misuse, alteration, contamination, or abnormal conditions of operation or handling. Resellers are not authorized to extend any other warranty on Fluke's behalf. To obtain service during the warranty period, contact your nearest Fluke authorized service center to obtain return authorization information, then send the product to that Service Center with a description of the problem.

THIS WARRANTY IS YOUR ONLY REMEDY. NO OTHER WARRANTIES, SUCH AS FITNESS FOR A PARTICULAR PURPOSE, ARE EXPRESSED OR IMPLIED. FLUKE IS NOT LIABLE FOR ANY SPECIAL, INDIRECT, INCIDENTAL OR CONSEQUENTIAL DAMAGES OR LOSSES, ARISING FROM ANY CAUSE OR THEORY. Since some states or countries do not allow the exclusion or limitation of an implied warranty or of incidental or consequential damages, this limitation of liability may not apply to you.

Fluke Corporation
P.O. Box 9090
Everett, WA 98206-9090 U.S.A.

Fluke Europe B.V.
P.O. Box 1186
5602 BD Eindhoven
The Netherlands